

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Instructions for Residential Testing of Lead & Copper in Drinking Water served by a Public Water System

Enclosed please find the requested amount of sample bottle(s).

1. Choose the tap(s) you wish to sample from.
2. The water should remain stagnant for at least 6 hours.
3. After the stagnation period, before any water is used, open the tap and fill one sample bottle to the shoulder with COLD water.
4. Fill out tag and COC with Sample ID, Sampling Date & Time and requested signatures. Return to one of our Satellite locations, laboratories or request a pick up. Please arrange for payment by providing check, cash, call in Credit card information, or pay on line through our website.

Lab Locations:

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Tel. 1-800-273-8901**

**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert.
#15037
Tel. 1-800-273-8901 X301**

Satellite Office and Drop off Locations:

**North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871
Tel. 973-729-1827, Tel. 1-800-273-8901 X200**

**West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826
Tel. 908-537-7414, Tel. 1-800-273-8901 X400**